

Operating Records of Nuclear Power Plants in August

Power Plant	Reactor Type	Gross Capacity (MWe)	Availability Factor		Capacity Factor		Remarks
			Operating hours [h]	[%]	Generated output [MWh]	[%]	
Tokai-Daini (II)	BWR	1100	744	100.0	817,447	99.9	Shutdown due to periodic inspection. (14. Jun.-9. Aug.)
Tsuruga-1	BWR	357	554	74.5	193,487	72.8	
Tsuruga-2	PWR	1160	744	100.0	883,138	102.3	
Tomari-1	PWR	579	744	100.0	438,176	101.7	
Tomari-2	PWR	579	744	100.0	439,726	102.1	
Onagawa-1	BWR	524	744	100.0	392,022	100.6	Shutdown due to periodic inspection. (8. Sep. 2002~26. Aug.)
Onagawa-2	BWR	825	0	0.0	0	0.0	Shutdown due to periodic inspection. (22. May~)
Onagawa-3	BWR	825	744	100.0	633,627	103.2	
Fukushima I-1	BWR	460	0	0.0	0	0.0	Shutdown due to periodic inspection. (20. Nov. 2002~)
Fukushima I-2	BWR	784	0	0.0	0	0.0	Shutdown due to periodic inspection. (31. Mar.~)
Fukushima I-3	BWR	784	392	52.7	285,356	48.9	Shutdown due to periodic inspection. (18. Jul. 2002~16. Aug.)
Fukushima I-4	BWR	784	0	0.0	0	0.0	Shutdown due to periodic inspection. (2. Dec. 2002~)
Fukushima I-5	BWR	784	0	0.0	0	0.0	Shutdown due to periodic inspection. (11. Feb.~)
Fukushima I-6	BWR	1100	744	100.0	818,400	100.0	
Fukushima II-1	BWR	1100	19	2.5	3,279	0.4	Shutdown due to periodic inspection. (7. Jan.-31. Aug.)
Fukushima II-2	BWR	1100	0	0.0	0	0.0	Shutdown due to periodic inspection. (14. Apr.~)
Fukushima II-3	BWR	1100	0	0.0	0	0.0	Shutdown due to periodic inspection. (10. Dec. 2002~)
Fukushima II-4	BWR	1100	0	0.0	0	0.0	Shutdown due to periodic inspection. (1. Feb.~)
Kashiwazaki Kariwa-1	BWR	1100	0	0.0	0	0.0	Shutdown due to periodic inspection. (3. Sep. 2002~)
Kashiwazaki Kariwa-2	BWR	1100	0	0.0	0	0.0	Shutdown due to periodic inspection. (10. Mar.~)
Kashiwazaki Kariwa-3	BWR	1100	0	0.0	0	0.0	Shutdown due to periodic inspection. (10. Aug. 2002~)
Kashiwazaki Kariwa-4	BWR	1100	744	100.0	826,390	101.0	
Kashiwazaki Kariwa-5	BWR	1100	0	0.0	0	0.0	Shutdown due to periodic inspection. (1. Mar.~)
Kashiwazaki Kariwa-6	ABWR	1356	744	100.0	1,034,804	102.6	
Kashiwazaki Kariwa-7	ABWR	1356	744	100.0	1,028,448	101.9	
Hamaoka-1	BWR	540	0	0.0	0	0.0	Shutdown due to periodic inspection. (26. Apr. 2002~)
Hamaoka-2	BWR	840	744	100.0	620,005	99.2	
Hamaoka-3	BWR	1100	0	0.0	0	0.0	Shutdown due to periodic inspection. (20. Feb.~)
Hamaoka-4	BWR	1137	525	70.6	555,445	65.7	Shutdown due to periodic inspection. (4. Sep. 2002~7. Aug.)
Shika-1	BWR	540	0	0.0	0	0.0	Shutdown due to periodic inspection. (21. Apr.~)
Mihama-1	PWR	340	744	100.0	252,886	100.0	Shutdown due to periodic inspection. (1. Aug.~)
Mihama-2	PWR	500	744	100.0	365,178	98.2	
Mihama-3	PWR	826	744	100.0	622,429	101.3	
Takahama-1	PWR	826	744	100.0	637,085	103.7	
Takahama-2	PWR	826	23	3.1	15,908	2.6	
Takahama-3	PWR	870	744	100.0	669,403	103.4	
Takahama-4	PWR	870	744	100.0	671,033	103.7	
Ohi-1	PWR	1175	744	100.0	869,432	99.5	
Ohi-2	PWR	1175	744	100.0	874,992	100.1	
Ohi-3	PWR	1180	744	100.0	892,545	101.7	
Ohi-4	PWR	1180	744	100.0	866,443	98.7	
Shimane-1	BWR	460	744	100.0	342,195	100.0	Shutdown due to periodic inspection. (15. Apr.-1. Aug.)
Shimane-2	BWR	820	733	98.5	584,921	95.9	
Ikata-1	PWR	566	744	100.0	425,767	101.1	
Ikata-2	PWR	566	744	100.0	426,764	101.3	
Ikata-3	PWR	890	744	100.0	689,091	104.1	
Genkai-1	PWR	559	744	100.0	422,463	101.6	
Genkai-2	PWR	559	744	100.0	426,651	102.6	
Genkai-3	PWR	1180	744	100.0	895,902	102.0	
Genkai-4	PWR	1180	744	100.0	888,264	101.2	
Sendai-1	PWR	890	744	100.0	665,115	100.4	
Sendai-2	PWR	890	73	9.8	62,733	9.5	
Total/Average (Previous Month)		45742 (45742)	24,639 (21,210)	63.7% (54.8)	21,536,950 (18,731,030)	63.3% (55.0)	